Kaimann GmbH | Hansastr. 2-5 | D-33161 Hövelhof

07.06.2022

To
VALPAR
attn. Barry Davidson

Dr. Jürgen Georg Weidinger
Chief Technology Innovation Officer

Tel.: +49 5257 9850-0
Fax: +49 5257 9850-590
E-Mail: juergengeorg.weidinger@kaimann.de
Internet: www.kaimann.de

Confirmation on Properties of Actual Material for Python Insulation

Herewith we confirm that the actual elastomeric foam material ("KB", FEF acc. to EN 14304) proposed for python insulation is at least performing equivalently to the discontinued one ("PY"); typical performance indicators are:

	KB material
Thermal conductivity	Max. 0.034 W/[mK] @ 0°C
Water vapour transmission blocking value	Min. 8000
Fire performance	Fire class B, smoke class s2 acc. to EN 13501-1 Class 0 acc to BS 476 Self-extinguishing acc. to ISO, EN and ASTM standards
Water intake	Max. 0.5%

a.m. values are based on lab testing and shall not be used for specifications.

Kaimann GmbH

Dr. Jürgen Weidinger
CTIO